



Certificate of Compliance

Certificate: 70026926

Master Contract: 258805

Project: 70170252

Date Issued: 2018-03-19

Issued to: LeadSolar Energy (Wuxi) Co.,Ltd.
No.530 Building A 308,
Qingyuan Road
Wuxi New District,
Wuxi, Jiangsu 214315
CHINA
Attention: Kemp Qiu

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Rohana Yang
Rohana Yang

PRODUCTS

CLASS - C531109 - POWER SUPPLIES-Distributed Generation Power Systems Equipment

CLASS - C531189 - POWER SUPPLIES - Distributed Generation-Power Systems Equipment - Certified to U.S. Standards

Utility Interactive Micro Inverter, Models LS700S, LS600-277, LS650-277 and LS700-277, rack mounted.
Grid Support Utility Interactive Inverter, Models LS600X and LS700X, rack mounted.

Note:

For details related to rating, size, configuration, etc., reference should be made to the CSA Certification Record, Certificate of Compliance Annex A, or the Descriptive Report.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 107.1-01 - General Use Power Supplies

*UL Std. No. 1741-Second Edition - Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources (Second Edition, Revision September 7, 2016)



Certificate: 70026926
Project: 70170252

Master Contract: 258805
Date Issued: 2018-03-19

*Note: Conformity to UL 1741 (Second Edition, Revision September 7, 2016) includes compliance with applicable requirements of IEEE 1547-2003 (R2008), IEEE 1547.1-2005(R2011), California Electric Rule 21 and Supplement SA.



Supplement to Certificate of Compliance

Certificate: 70026926

Master Contract: 258805 (258805)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70170252	2018-03-19	Update to report 70026926 to include Grid Support Utility Interactive Micro Inverter model LS600X and LS700X. These two model are evaluated to meet California Rule 21 according to UL 1741SA. The evaluated software version: V105LS700G2HV1.1_789Boot.
70130693	2018-01-08	UTILITY INTERACTIVE INVERTER-Update to Report 70026926 to Include Model LS600-277
70069944	2016-06-21	Update to report 70026926 to add field adjustable voltage and frequency settings for Model LS700TS-208 and LS700TS-240.
70026926	2015-04-07	Utility Interactive Micro Inverter, Models LS700TS-208 and LS700TS-240, rack mounted.(C/US)